



Recc all piping to be sized per ASHRAE F36

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM 100°F INLET TEMPERATURE
 BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

PROJECT NAME:		DRAWING TITLE:	
PROJECT LOCATION:		HYDRO-PUMP/SECONDARY - SEALED COMBUSTION BOILER, CIRCUIT SETTER PROTECTION, WITH SYSTEM 2 PUMPS	
ENGINEER:	RSG 05/28/08	DRAWING No.	H-PS-100-1CS-2
DESCRIPTION:		DRAWN BY/DATE:	BYR/05/23/08
REV:		CHECKED BY/DATE:	BYR/05/23/08
		DATE:	05/23/08
		SCALE:	AS SHOWN
		SIZE:	11x17
		REV:	A

THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF CHC. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN. NO PARTS OF THIS DRAWING OR THE INFORMATION DEPICTED THEREIN ARE TO BE REPRODUCED OR COPIED, OR USED AS THE BASIS FOR THE MANUFACTURING, WITHOUT PRIOR WRITTEN PERMISSION OF CHC.

