



Recc all piping to be sized per ASHRAE F36

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM F INLET TEMPERATURE BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

PROJECT NAME:		THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF CHC. IT IS TO BE USED ONLY FOR THE PROJECT SPECIFICALLY IDENTIFIED HEREIN. ANY REPRODUCTION OR USE FOR ANY OTHER PROJECT WITHOUT WRITTEN PERMISSION OF CHC.	
PROJECT LOCATION:		ENGINEER:	
DRAWING TITLE:		DRAWING No.	
HYDRONIC PRIMARY/SECONDARY - 3 ATMOSPHERIC BOILERS, CIRCUIT SETTER PROTECTION, WITH 2 SYSTEM PUMPS		H-PS-100-3CS-2	
PROJECT LOCATION:		DRAWN BY/DATE	
ENGINEER:		CHECKED BY/DATE	
CUSTOMER:		APPROVED BY/DATE	
BY:		SCALE	
DATE:		DATE	
DESCRIPTION:		REV	
A RELEASED		A	
REV		REV	

