



Rec all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM °F INLET TEMPERATURE
BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

REV	DESCRIPTION	DATE	BY
A	RELEASED	RSG 05/28/08	

PROJECT NAME:	HYDRONIC PRIMARY/SECONDARY - SEALED COMBUSTION BOILER, CIRCUIT SETTER PROTECTION, WITH SYSTEM PUMP
PROJECT LOCATION:	
ENGINEER:	H-PS-200-1CS-1
CUSTOMER:	

CALIFORNIA • RENO
 800.486.4858
 WASHINGTON • OREGON
 ALASKA • IDAHO • MONTANA
 888.690.0090