



Rec'd all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM F INLET TEMPERATURE BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

<p>THIS DRAWING AND THE INFORMATION OF DEPICTED THEREIN IS THE PROPERTY OF CHC, CALIFORNIA HYDRONICS CORP. CONFIDENCE AND SHALL NOT BE REPRODUCED OR COPIED, OR USED AS THE BASIS FOR THE MANUFACTURING, INSTALLATION OR SALE OF PRODUCT UNLESS AUTHORIZED BY WRITTEN PERMISSION OF CHC.</p>	
PROJECT NAME:	HYDRONIC PRIMARY/SECONDARY - 3 SEALED COMBUSTION BOILERS, CIRCUIT SETTER PROTECTION, WITH SYSTEM PUMP
PROJECT LOCATION:	
ENGINEER:	RSG 05/28/08
CUSTOMER:	
BY:	
DATE:	
REV	DESCRIPTION
A	RELEASED

CHC
 CALIFORNIA • RENO
 800.486.4858
 WASHINGTON • IDAHO • OREGON
 ALASKA • MONTANA
 888.690.0090