



Rec'd all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

\*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM  F INLET TEMPERATURE  
 BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

THIS DRAWING AND THE INFORMATION OF DEPICTED THEREIN IS THE PROPERTY OF CHC, CALIFORNIA HYDRONICS CORP., CONFIDENTIAL AND SHALL NOT BE REPRODUCED OR COPIED, OR USED AS THE BASIS FOR THE MANUFACTURING, INSTALLATION OR SALE OF PRODUCT WITHOUT WRITTEN PERMISSION OF CHC.	
PROJECT NAME:	HYDRONIC PRIMARY/SECONDARY - 3 SEALED COMBUSTION BOILERS, CIRCUIT SETTER PROTECTION, WITH 2 SYSTEM PUMPS
PROJECT LOCATION:	
ENGINEER:	RSG 05/28/08
CUSTOMER:	
BY:	
DATE:	
REV	DESCRIPTION
A	RELEASED

CALIFORNIA • RENO  
 800.486.4858  
 WASHINGTON • OREGON  
 ALASKA • IDAHO • MONTANA  
 888.690.0090