



Recc all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM 100°F INLET TEMPERATURE
 BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

PROJECT NAME:		DRAWING TITLE:	
PROJECT LOCATION:		HYDRONIC PRIMARY/SECONDARY - SEALED COMBUSTION BOILER WITH SEPARATE PRIMARY PUMP POWER, CIRCUIT SETTLER PROTECTION, WITH 2 SYSTEM PUMPS	
ENGINEER:	H-PS-201-1CS-2	DRAWING No.	H-PS-201-1CS-2
CUSTOMER:		DRAWN BY/DATE:	BJ/ZJ/08
BY:	RSG 05/28/08	CHECKED/DATE:	5/28/08
DATE:		SCALE:	AS SHOWN
DESCRIPTION:		SCALE:	AS SHOWN
REV:		SCALE:	AS SHOWN

THIS DRAWING AND THE INFORMATION DERIVED THEREIN IS THE PROPERTY OF CHC, CALIFORNIA HYDRONICS CORP. COPIES ARE ISSUED IN STRICT CONFIDENCE AND ARE NOT TO BE REPRODUCED OR COPIED OR USED AS THE BASIS FOR THE MANUFACTURING, INSTALLATION OR SALE OF PRODUCT WITHOUT PRIOR WRITTEN PERMISSION OF CHC.

CHC
 CALIFORNIA HYDRONICS CORP.

WASHINGTON • OREGON
 ALASKA • IDAHO • MONTANA
 CALIFORNIA • RENO
 800.486.4858
 888.690.0090